



NOTES:

1. 28 DAY COMPRESSIVE STRENGTH OF CONCRETE SHALL BE A MINIMUM OF 3,500 PSI.
2. STANDARD SIDEWALK CROSS SLOPE SHALL BE 1/4" PER FOOT OR 2%.
3. CONCRETE THICKNESS FOR SIDEWALKS SHALL BE A MINIMUM OF 4" W/ A MINIMUM OF 3" OF 3/4" COMPACTED ROCK UNDER SIDEWALK. DRIVEWAYS SHALL BE A MINIMUM OF 6" W/ A MINIMUM OF 3" OF 3/4" COMPACTED ROCK.
4. CONTRACTION JOINTS SHALL BE INSTALLED AT 10' INTERVALS, BY CUTTING A MIN. ONE THIRD OF THE DEPTH OF CONCRETE. "DUMMY" JOINTS SHALL BE INSTALLED AT 5' INTERVALS.
5. BROOM FINISH PERPENDICULAR TO TRAFFIC. OUTSIDE EDGES OF SIDEWALK AND PANEL MARKS SHALL BE "SHINED" W/ A STANDARD EDGING TOOL HAVING A 1/2" RADIUS.
6. "DUMMY" JOINTS MAY BE CUT AS STANDARD WEAKENED PLANE CONSTRUCTION JOINTS.
7. THE AREA BEHIND THE SIDEWALK IS TO BE BACKFILLED WITH COMPACTED NATIVE MATERIAL AT A 2:1 SLOPE OR FLATTER.
8. SIDEWALK SHALL NOT BE CONSTRUCTED MONOLITHICALLY W/ CURBING OR OTHER ADJACENT NON-PEDESTRIAN SURFACES WITHOUT PRIOR APPROVAL OF CITY ENGINEER.

Section A-A

STANDARD SIDEWALK WIDTH (INCLUDING CURB)	
LOCAL (GRID) AND COLLECTOR (MINOR) STREETS	5'-0"
COLLECTOR (MAJOR) AND ARTERIAL STREETS	6'-0"

DIRECTOR OF PUBLIC WORKS ACCEPTANCE	
INITIALS _____	DATE 5/08



CITY OF DALLAS
DEPARTMENT OF PUBLIC WORKS

**STANDARD
SIDEWALK DETAIL**